

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013138-R5
DATE: 04/15/2016
CERTIFICATION PROGRAM: Structural
COMPANY: BlueLinx
CODE: 1366-1
REVISION DATE: 02/03/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BlueLinx Corporation 225 Collins Road Elkhart, IN 46516	“Gladiator/Finishield” 25 Gauge Thin Stile & Rail Inswing Opaque Steel Door Configuration: X Frame: W-949mm(37.36") H-2079mm(81.85") Panel: W-907mm(35.79") H-2012mm(79.21")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/02/12 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sections)	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-024
Expiration Date: **January 31, 2028**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com