

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013139-R4
DATE: 04/15/2016
CERTIFICATION PROGRAM: Structural
COMPANY: BlueLinx
CODE: 1366-1
REVISION DATE: 07/27/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| BlueLinx Corporation 225 Collins Road Elkhart, IN 46516 | “Contours Steel Door” 24 Gauge Inswing Glazed Steel Door Configuration: X Frame: W-948mm(37.32") H-2085mm(82.09") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.14") H-1607mm(63.27") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA 1702.2-95/02/12 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sections) | Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf |

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-021/W-1767
Expiration Date: January 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com