NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013171-R3

DATE: 05/05/2016

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: <u>BlueLinx</u>

CODE: 1366-1

REVISION DATE: 07/27/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BlueLinx Corporation	"Opaque Steel Door"
225 Collins Road	24 Gauge Inswing Opaque Steel Door
Elkhart, IN 46516	
	Configuration: X
	Frame: W-953mm(37.5") H-2064mm(81.25")
	Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction	Manufactured Housing-Passed Wind Zone III
& Safety Standard 3280.305	Design Wind Pressure Rating:
(applicable sections)	+58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.

Report No: TEL 01371559 Expiration Date: **April 30, 2026**

Administrator's Signature:

NATIONAL ACCREDITATION AND

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

MANAGEMENT INSTITUTE, INC.

nami@namiinc.com