

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013210.03-R2
DATE: 07/19/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 01/16/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "400" Vinyl Double Single Hung w/Center Fixed Lite Composite Window Configuration: O/X//O//O/X Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-2134mm(84") Sash: W-856mm(33.69") H-1033mm(40.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CAWM 1-79/CMBSO 301	Class R-PG15 2743 x 2134 (108 x 84)-H Design Pressure: ±720 Pa (15 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-5616
Expiration Date: April 30, 2028

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com