

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013211.04-R2  
DATE: 01/30/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>Series "200"</b> <b>Vinyl Horizontal Slider</b> <b>w/Passive Air Vent (Sash)</b>  Configuration: XO Glazing: Insulating Glass (Annealed)  Frame: W-1829mm(72") H-1829mm(72") Panel: W-889mm(35") H-1762mm(69.37")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CAWM 1-79/CMBSO 301	<b>Class LC-PG25 1829 x 1829 (72 x 72)-HS</b> <b>Design Pressure: ±1200 Pa (25 psf)</b> Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: N C T L - 3 1 0 - 5866/W-2010  
Expiration Date: August 31, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)