

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013278.07-R2  
**DATE:** 06/22/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Great Lakes  
**CODE:** 1411-1  
**REVISION DATE:** 02/14/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Great Lakes Window</b> <b>30499 Tracy Road</b> <b>Walbridge, OH 43465</b>	<b>Series "ecoSmart"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1803mm(71") H-1422mm(56.06") Panel: W-876mm(34.5") H-1319mm(51.94") DLO: W-797mm(31.38") H-1240mm(48.81")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b>	<b>Class LC-PG30 1803 x 1422 (71 x 56)-HS</b> <b>HS-LC30 1803 x 1422 (71 x 56)</b> <b>Design Pressure: 1440 Pa (30 psf)</b> <b>Negative Design Pressure: 1440 Pa (30 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19155-2  
Expiration Date: **December 31, 2026**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)