

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013278.10-R2
DATE: 09/15/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Great Lakes
CODE: 1411-1
REVISION DATE: 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Great Lakes Window 30499 Tracy Road Walbridge, OH 43465	Series "ecoSmart" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm(44") Panel: W-787mm(31") H-1014mm(39.94") DLO: W-697mm(27.44") H-937mm(36.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class R-PG45 1600 x 1118 (63 x 44)-HS HS-R45 1600 x 1118 (63 x 44) Design Pressure: 2640 Pa (55 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19160-3/W-2071
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com