

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013278.12-R2  
**DATE:** 11/13/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Great Lakes  
**CODE:** 1411-1  
**REVISION DATE:** 09/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Great Lakes Window</b> <b>30499 Tracy Road</b> <b>Walbridge, OH 43465</b>	<b>Series "ecoSmart"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2925mm(115.19") H-1600mm(63") Panel: W-978mm(38.5") H-1495mm(58.88") DLO: W-886mm(34.88") H-1414mm(55.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b>	<b>Class R-PG30 2921 x 1600 (115 x 63)-HS</b> <b>HS-R30 2921 x 1600 (115 x 63)</b> <b>Design Pressure: 1440 Pa (30 psf)</b> <b>Negative Design Pressure: 1440 Pa (30 psf)</b> <b>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19161-2/NCTL-110-19161-1/W-1986  
Expiration Date: **June 30, 2027**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)