

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013278.13-R2
DATE: 11/13/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Great Lakes
CODE: 1411-1
REVISION DATE: 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Great Lakes Window 30499 Tracy Road Walbridge, OH 43465 | Series "ecoSmart" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1599mm(62.94") H-1118mm(44") Panel: W-786mm(30.94") H-1016mm(40") DLO: W-695mm(27.38") H-937mm(36.88") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09 | Class R-PG30 1599 x 1118 (63 x 44)-HS HS-R30 1599 x 1118 (63 x 44) Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19155-3/W-1986
Expiration Date: December 31, 2027

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com