

NOTICE OF PRODUCT CERTIFICATION



Company: Guy C. Lee Millwork
1251 South Pollock Street
Selma, NC 27576

Certification No.: NI013333-R2
Certification Date: 08/09/2016
Revision Date: 04/13/2023
Expiration Date: 04/30/2025

Product: 24 Ga. Steel Wood Edge Glazed & Opaque Doors w/Glazed Sidelites (w/wood frame)

Specification: ASTM E283-04/E330-02/E331-00/AAMA 1304-02

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Test Report Number Drawing Number & Comments
OXXO Double w/Sidelites	I/S	Door-Glazed Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/NCTL 210-3801-1/FL 1940 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-276 Sill Installation Details: JW152012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	I/S	Door-Glazed Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/SJW2010-146/FL 1940 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/Endura LZA1L5625DSR Sill Installation Details: JW152012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	O/S	Door-Glazed Sidelite-Glazed	12'5" x 8'1"	+35/-35 psf	NCTL 210-3804-4/NCTL 210-3801-1/FL 1940 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-117 Sill Installation Details: JW152012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/NCTL 210-3801-1/FL 1938 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-276 Sill Installation Details: JW142012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	12'5" x 8'2"	+35/-35 psf	NCTL 210-3804-3/SJW2010-146/FL 1938 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/Endura LZA1L5625DSR Sill Installation Details: JW142012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO
OXXO Double w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	12'5" x 8'1"	+35/-35 psf	NCTL 210-3804-4/NCTL 210-3801-1/FL 1938 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 1'10" x 6'8" Glazing: IG- 1/8" Tempered w/AFCO A-117 Sill Installation Details: JW142012FL Qualifies Configurations: O/X/XO/OX/OXO/XX/XXO/OXX/OXXO

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____