NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013361-R4**
DATE:	**09/07/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Glass Craft**
CODE:	**1157-1**
REVISION DATE:	**02/10/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Glass Craft Door Corporation **2002 Brittmoore** **Houston, TX 77043-2209**	**Series "Fiberglass Door"** **Opaque In-Swing & Out-Swing** **Fiberglass Side-Hinged Door** **w/Speak Easy** Configuration: X Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass Frame: W-953mm (37.5") H-2489mm(98") Panel: W-914mm (36") H-2438mm(96") DLO: W-152mm (6") H-292mm(11.5")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a/E1996-14a	**Design Pressure: ±2400 Pa (±50 psf)** **Wind Zone 3 - Missile Level D**

Product Tested By: Architectural Testing Incorporated
Report No: E4545.02-801-44/E4545.03-801-44
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com