

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013361.01-R5  
**DATE:** 09/07/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Glass Craft  
**CODE:** 1157-1  
**REVISION DATE:** 12/20/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Glass Craft Door Corporation</b> <b>2002 Brittmoore</b> <b>Houston, TX 77043-2209</b>	<b>Series "Fiberglass Door"</b> <b>Opaque In-Swing &amp; Out-Swing</b> <b>Fiberglass Side-Hinged Door</b> <b>w/Speak Easy</b>  Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass  Frame: W-953mm (37.5") H-2489mm(98") Panel: W-914mm (36") H-2438mm(96") DLO: W-152mm (6") H-292mm(11.5")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b>	<b>Design Pressure: ±2400 Pa (±50 psf)</b>

Product Tested By: Architectural Testing Incorporated  
Report No: E4545.01-801-44/W-2108  
Expiration Date: **February 28, 2025**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)