

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013362-R4
DATE: 09/07/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Glass Craft
CODE: 1157-1
REVISION DATE: 11/14/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Glass Craft Door Corporation 2002 Brittmoore Houston, TX 77043-2209	Series "Triple Fiberglass Door" Glazed In-Swing & Out-Swing Fiberglass Side-Hinged Door Configuration: OXXX Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass Frame: W-3278mm (129") H-2489mm(98") Panel: W-914mm (36") H-2438mm(96") DLO: W-572mm (20.5") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a/E1996-14a	Design Pressure: ±2400 Pa (±50 psf) Wind Zone 3 - Missile Level D

Product Tested By: Architectural Testing Incorporated
Report No: E4545.05-801-44/E4545.06-801-44
Expiration Date: **January 31, 2025**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com