

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013371.03-R6  
**DATE:** 10/03/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 12/17/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "1500"</b> <b>Vinyl Single Hung</b> (Reinforced: Mullion/Fixed Meeting Stiles)  Configuration: O/X//O/X//O/X Glazing: Insulating Glass (Annealed)  Frame: W-2732mm(107.56") H-1865mm(73.44") Sash: W-837mm(32.94") H-906mm(35.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1701.2-95/02/12</b> <b>AAMA 1704-85/01/12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b> <b>Design Wind Pressure Rating:</b> <b>+58/-58 psf</b> <b>Egress-Passed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19485-2/W-1831/W-1867  
Expiration Date: **June 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

[nami@namiinc.com](http://nami@namiinc.com)

NOPC 03/30/2023