

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013381.01-R4  
**DATE:** 10/13/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Prime Window  
**CODE:** 2287-1  
**REVISION DATE:** 05/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>12775 East 38<sup>th</sup> Avenue</b> <b>Denver, CO 80239</b>	<b>Series "1000"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1828mm(72") H-1828mm(72") DLO: W-1695mm(66.75") H-1695mm(66.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class CW-PG70 1828 x 1828 (72 x 72)-FW</b> <b>Design Pressure: ±3360 Pa (70 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) <b>Canadian Air Infiltration/Exfiltration Level: Fixed</b>

Product Tested By: Architectural Testing, Inc.  
Report No: C7401.02-901-44  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)