

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013385.02-R2  
**DATE:** 03/22/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/07/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "700"</b> <b>Two-Lite Vinyl Fixed Window</b>  Configuration: OO Glazing: Insulating Glass (Annealed)  Frame: W-2426mm(95.5") H-2426mm(95.5") DLO: W-1100mm(43.31") H-2311mm(91")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CMBSO 1-79/CAWM 301</b>	<b>Class LC-PG25 2426 x 2426 (96 x 96)-FW</b> <b>Design Pressure: ±1200 Pa (25 psf)</b> <b>Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-6074/W-2010  
Expiration Date: **December 31, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)