NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI013386.08-R4
DATE: 10/17/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2287-1
REVISION DATE: 07/09/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems **12775 East 38th Avenue** **Denver, CO 80239**	**Series "411"** **Vinyl Sliding Door** Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3580mm(140.94") H-2440mm(96") Panel: W-923mm(36.32") H-2360mm(92.94")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440S1-09** **CAWM 301-90**	**Class LC-PG25 3580 x 2440 (141 x 96)-SD** **Design Pressure: ±1200 Pa (25 psf)** **Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Architectural Testing, Inc.
Report No: E2120.02-901-44
Expiration Date: **October 31, 2028**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com