NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013442-R4**
DATE:	**12/11/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Prime Window**
CODE:	**2287-1**
REVISION DATE:	**03/14/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems **12775 East 38th Avenue** **Denver, CO 80239**	**Series "9000" Mulled Vinyl** **Single Hung Window w/Fin Installation** **& Fixed Window** Configuration: O/O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2743mm(108") Sash: W-1146mm(45.13") H-906mm(35.69") DLO: W-1127mm(44.38") H-810mm(31.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class LC-PG40 1219 x 2743 (48 x 108)-H** **H-LC40 1219 x 2743 (48 x 108)** **Design Pressure: ±1915 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: C0072.02-801-47
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com