

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013442.05-R4  
DATE: 12/11/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Prime Window  
CODE: 2287-1  
REVISION DATE: 05/24/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>12775 East 38<sup>th</sup> Avenue</b> <b>Denver, CO 80239</b>	<b>Series "9000"</b> <b>Triple Vinyl Single Hung</b>  (Continuous Head & Sill) (w/Sill Extender)  Configuration: O/X//O/X//O/X Glazing: Insulating Glass (Annealed)  Frame: W-2743mm(108") H-1829mm(72") Sash: W-841mm(33.13") H-900mm(35.16") DLO: W-756mm(29.75") H-818mm(32.19")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG50 2743 x 1829 (108 x 72)-H</b> <b>H-LC50 2743 x 1829 (108 x 72)</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: C5184.02-801-47/C5183.02-801-47  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)