NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013453.23-R4**
DATE:	**12/19/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Prime Window**
CODE:	**2287-1**
REVISION DATE:	**09/03/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems **12775 East 38th Avenue** **Denver, CO 80239**	**Series "9000" Mulled Triple Vinyl** **Single Hung Window Assembly** (w/Fin Installation) Configuration: O/XO/XO/X Glazing: Insulating Glass (Annealed) Frame: W-2745mm(108.13") H-2134mm(84") DLO: W-751mm(29.63") H-975mm(38.38")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Applied Rating: LC45** **Mulled Fenestration Rating: LC45** **Individual Product Rating:** **Class LC-PG40 1220 x 2435 (48 x 96)-H** **Design Pressure: ±1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: F8778.02-901-44/F8004.01-901-44
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com