

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013464.03-R3  
**DATE:** 01/07/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Prime Window  
**CODE:** 2287-1  
**REVISION DATE:** 11/07/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>12775 East 38<sup>th</sup> Avenue</b> <b>Denver, CO 80239</b>	<b>Series "720"</b> <b>Vinyl Triple Awning</b> <b>(Fin or Finless Installation)</b>  Configuration: XXX Glazing: Insulating Glass (Annealed)  Frame: W-2743mm(108") H-914mm(36") Vent: W-884mm(34.82") H-870mm(34.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG35 2743 x 914 (108 x 36)-AP</b> <b>Design Pressure: ±1680 Pa (35 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: E1446.02-801-47/E1448.01-801-47  
Expiration Date: **October 31, 2024**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)