

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013484-R2
DATE: 01/18/2017
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1
REVISION DATE: 06/07/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites 1218 Corporate Dr. E. Arlington, TX 76006	Series "Patriot" Aluminum Fixed Glass Skylight Configuration: O Glazing: IG-1/4" Tempered Glass/Laminate-1/8" Tempered Glass/0.090" PVB Interlayer/1/8" Tempered Glass Frame: W-2496mm(98.25") H-2496mm(98.25") DLO:W-1715mm(67.5") L-1715mm(67.5") H-2210mm(87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG50 2496 x 2496 (98 x 98)-SKG Design Pressure: ±2400 Pa (50 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11psf)

Product Tested By: Architectural Testing, Inc.
Report No: C5811.01-801-44
Expiration Date: January 31, 2026

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com