NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI013487.01-R5
DATE: 01/26/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Central Lumber
CODE: 2305-1
REVISION DATE: 01/02/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Central Lumber Sales, Inc. **6600 Arbor Road** **Lincoln, NE 68517**	**"Smooth Star & Fiber Classic" Fiberglass** **Glazed In-Swing Side-Hinged Door** **w/Sidelites** Glazing: Insulating Glass (Tempered) Qualified Configurations: O, X, OX, XO, OXO, OOX, XOO Frame: W-2870mm(113") H-2083mm(82") Panel: W-914mm(36") H-2013mm(79.25") Sidelite: W-914mm(36") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/02/12 **Federal Manufactured Home Construction & Safety Standard 3280.305** **(applicable sub-sections)**	**Manufactured Housing:** **Wind Zone II** **Design Wind Pressure Rating** **+38/-38 psf** **(Excluding 36" from each corner of the sidewalls or endwalls)**

Product Tested By: Architectural Testing, Inc.
Report No: A4929.01-501-47/W-1739/W-1748/W-1802/W-2147
Expiration Date: **January 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com