

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013491-R3
DATE: 01/31/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Maxim
CODE: 1256-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maxim Industries, Inc. 201 Longhorn Road Fort Worth, Texas 76179	Series "BCM" Aluminum Skylight Configuration: O Glazing: Outer Dome-Covestro SL or PalRam UV Enhanced Polycarbonate Dome/Inner Dome-Gallina PoliCarb 5Layer RDC Multi-Wall Polycarbonate Frame: W-1842mm(72.5") H-1842mm(72.5") DLO: W-1778mm(70") H-1778mm(70")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a/E1996-12 TAS 201/202/203-94	SKP-PG60 1842 x 1842 (73 x 73) Design Pressure: 2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: G5934.01-801-18/G5934.02-801-18/G5934.03-801-18
Expiration Date: January 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com