NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013503.07-R7**
DATE:	**02/09/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Dashwood Ind.**
CODE:	**1770-1**
REVISION DATE:	**02/11/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dashwood Industries, Inc. **28648 Centre Road** **Strathroy, ON N7G 3H8**	**Series "Classic Craft" Glazed** **Fiberglass In-Swing Side-Hinged Door** **w/Flush Glazed or Direct Set Sidelites** Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1892mm(74.5") H-2483mm(97.75") Panel: W-1061mm(41.75") H-2419mm(95.25") DLO: W-768mm(30.25") H-1267mm(49.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **A440S1-09**	**Class R-PG45 1905 x 2489 (75 x 98)-LW SHD** **Design Pressure: ±2160 Pa (45 psf)** **Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Architectural Testing, Inc.
Report No: F1693.03-501-47/W-1803/W-1805/W-1808/W-1847
Expiration Date: **September 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com