NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI013513.01-R2
DATE: 02/13/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center** **Welcome, NC 27374**	**Series "8700/1600/3500/80/6000"** **Vinyl Horizontal Sliding Window** **w/Finless Installation & Single Lock** Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-711mm(28") Panel: W-902mm(35.5") H-622mm(24.5") DLO: W-832mm(32.75") H-552mm(21.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class R-PG30 1829 x 711* (72 x 28*)-HS** **Design Pressure: ±1440 Pa (30 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19740-1/ NCTL-110-19739-1/W-1996
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com