

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013514.01-R7  
**DATE:** 02/14/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Dashwood Ind.  
**CODE:** 1770-1  
**REVISION DATE:** 12/22/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dashwood Industries, Inc.</b> <b>28648 Centre Road</b> <b>Strathroy, ON N7G 3H8</b>	<b>Series "Fiber-Classic/Smooth-Star"</b> <b>Opaque Fiberglass In-Swing</b> <b>Side-Hinged Door</b> <b>w/Glazed Sidelites &amp; Multi-Point Lock</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1740mm(68.5") H-2073mm(81.63") Panel: W-910mm(35.94") H-2008mm(79.06") DLO: W-151mm(5.94") H-1599mm(62.94")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>A440S1-09</b>	<b>Class R-PG75 1740 x 2073 (69 x 82)-LW SHD</b> <b>Design Pressure: ±3600 Pa (75 psf)</b> Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.  
Report No: D6427.06-501-47/W-1803/W-1805/W-1808/W-1847  
Expiration Date: **February 28, 2025**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)