## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: NI013514.02-R6

**DATE:** 02/14/2017

**CERTIFICATION PROGRAM:** Structural

COMPANY: <u>Dashwood Ind.</u>

**CODE:** 1770-1

**REVISION DATE:** 12/22/2021

To verify that the "Notice of Product Certification" is valid, please visit <a href="www.NAMICertification.com">www.NAMICertification.com</a> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Dashwood Industries, Inc.	Series "Fiber-Classic/Smooth-Star"		
28648 Centre Road	Lip-Lite Glazed Fiberglass In-Swing		
Strathroy, ON N7G 3H8	Side-Hinged Door		
		w/Glazed Sid	delites
		Configuration: Glazing: Insulating Gla	
	Frame:	W-1740mm(68.5")	H-2073mm(81.63")
	Panel:	W-910mm(35.94")	H-2008mm(79.06")
	DLO:	W-151mm(5.94")	H-1599mm(62.94")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class R-PG35 1740 x 2073 (69 x 82)-SHD  Design Pressure: ±1680 Pa (35 psf)  Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)  Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.

Report No: D6428.06-501-47/W-1803/W-1805/W-1808

Expiration Date: February 28, 2025

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: nami@namiinc.com