

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013514.08-R5
DATE: 02/14/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Dashwood Ind.
CODE: 1770-1
REVISION DATE: 12/22/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dashwood Industries, Inc. 28648 Centre Road Strathroy, ON N7G 3H8	Series "Fiber-Classic/Smooth-Star" Flush Glazed Fiberglass Out-Swing Side-Hinged Door w/Glazed Sidelites Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1740mm(68.5") H-2057mm(81") Panel: W-910mm(35.94") H-2008mm(79.06") DLO: W-660mm(26") H-1605mm(63.19")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class R-PG50 1740 x 2057 (69 x 81)-SHD Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.
Report No: E2544.04-501-47/W-1803/W-1808
Expiration Date: **February 28, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com