NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013515-R2**
DATE:	**02/14/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Atrium**
CODE:	**2187-1**
REVISION DATE:	**03/06/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. **300 Welcome Center** **Welcome, NC 27374**	**Series "8700/1600/3500/80/6000"** **Vinyl Horizontal Sliding Window** **w/Finless Installation** Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-1981mm(78") H-711mm(28") Panel: W-546mm(21.5") H-625mm(24.63") DLO: W-827mm(32.56") H-556mm(21.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class LC-PG30 1981 x 711* (78 x 28*)-HS** **Design Pressure: ±1440 Pa (30 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19606-1/NCTL-110-19739-1/W-2009
Expiration Date: **October 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com