NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013635-R1**
DATE:	**03/09/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Jolong**
CODE:	**2280-1**
REVISION DATE:	**09/23/2021**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Jolong Window & Door Systems (USA), Inc. **24119 Riverwalk Court, Unit 131** **Plainfield, IL 60544**	**Series "JL70–AW-TB"** **Thermally-Broken Aluminum Awning Window** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1250mm(49.21") H-1500mm(59.06") Vent: W-1206mm(47.48") H-1456mm(57.32") DLO: W-1081mm(42.56") H-1331mm(52.4")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class CW-PG30 1250 x 1500 (49 x 59)-AP** **Design Pressure: ±1440 Pa (30 psf)** **Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf)**

Product Tested By: Intertek Testing Services, Ltd.
Report No: 161209006SHF-BP-10
Expiration Date: **September 30, 2022**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122