

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013641-R1  
**DATE:** 03/10/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Tech  
**CODE:** 008-1  
**REVISION DATE:** 01/27/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Window Tech Systems, Inc.</b><br><b>15 Stonebreak Road</b><br><b>Malta, NY 12020</b> | <b>Series "5000"</b><br><b>Aluminum Fixed Window</b><br><br>Configuration: O<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1524mm(60") H-2515mm(99")<br>DLO: W-1422mm(56") H-2413mm(95") |

| SPECIFICATION                          | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> | <b>Class AW-PG80 1524 x 2515 (60 x 99)-FW</b><br><b>Design Pressure: ±3840 Pa (80 psf)</b><br>Water Penetration Resistance Test Pressure: 580 Pa (12.0 psf) |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19745-5  
Expiration Date: December 31, 2030

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122