

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013644-R1
DATE: 03/10/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Window Tech
CODE: 008-1
REVISION DATE: 01/27/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Tech Systems, Inc. 15 Stonebreak Road Malta, NY 12020	Series "6500/7500/8500/9500" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2775mm(109.25") H-1835mm(72.25") DLO: W-857mm(33.75") H-1753mm(69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG80 2775 x 1835 (109 x 72)-FW Design Pressure: ±3840 Pa (80 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19831-1
Expiration Date: **February 28, 2031**

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122