NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013658-R1**
DATE:	**03/15/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Pioneer**
CODE:	**1572-1**
REVISION DATE:	**06/16/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pioneer Industries **111 Kero Road** **Carlstadt, NJ 07072**	**Opaque Steel** **Out-Swing Side-Hinged Door** Configuration: X Frame: W-1016mm(40") H-2191mm(86.25") Panel: W-908mm(35.75") H-2113mm(83.19")

SPECIFICATION	PRODUCT RATING
ICC 500-08 (Section 804.9.5) **ASTM E330-14** **ASTM E1886-04** **(Sections 6, 9, 11.1 thru 11.6 only)**	**Passed** **Design Pressure: +203/-203 psf**

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: 7809
Expiration Date: **March 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com