

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013664-R3
DATE: 03/21/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 2187-1
REVISION DATE: 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 300 Welcome Center Blvd. Welcome, NC 27374	Series "130" Aluminum Mullion Span: 2731mm(107.5") Tributary Width: 1219mm(48")

SPECIFICATION	PRODUCT RATING
AAMA 450-06/10 (Option 3)	Applied Rating: Class R-PG15 Mulled Fenestration Rating: Class R-PG15-MA Design Pressure: ± 718 Pa (15 psf) Water Penetration Resistance Test Pressure: 958 Pa (20 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19585-1/FPA-130-Mull
Expiration Date: **February 28, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com