NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013675.01-R2**
DATE:	**04/03/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**West Window**
CODE:	**113-1**
REVISION DATE:	**04/08/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
West Window Corporation **226 Industrial Park Drive** **Martinsville, VA 24112**	**Series "WestEdge"** **Vinyl Fixed Window** **(Wet Glazed)** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1524mm(60") DLO: W-1397mm(55") H-1397mm(55")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	**FW-C80 1524 x 1524 (60 x 60)** **Design Pressure: ±3840 Pa (80 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)**

Product Tested By: Architectural Testing Incorporated
Report No: B0196.01-501-47
Expiration Date: **April 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com