NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013677-R2**
DATE:	**04/04/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**West Window**
CODE:	**113-1**
REVISION DATE:	**04/08/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
West Window Corporation **226 Industrial Park Drive** **Martinsville, VA 24112**	**Series "WestEdge"** **Vinyl Horizontal Sliding Window** Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-2134mm(84") H-1524mm(60") Panel: W-1046mm(41.81") H-1449mm(57.06") DLO: W-984mm(38.75") H-1397mm(55")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class LC-PG25 2134 x 1524 (84 x 60)-HS** **HS-LC25 2134 x 1524 (84 x 60)** **Design Pressure: ±1200 Pa (25 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: B6448.01-501-47
Expiration Date: **April 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com