NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI013690.05-R3
DATE: 04/26/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 06/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA **4016 Shadrack St.** **Houston, TX 77013**	**Series "9-0 x 8-0" Fiberglass** **Outswing Side-Hinged Double Door** Configuration: OXX Glazing: IG-Int: 1/8" Tempered Glass/Ext: 1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass Frame: W-2769mm(109") H-2426mm(95.5") Panel: W-908mm(35.75") H-2338mm(92.06") DLO: W-533mm(21") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	**Design Pressure: ±2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)** **Large Missile Impact Rated**

Product Tested By: Certified Testing Laboratories
Report No: CTLA 1420W/CTLA 2019W
Expiration Date: **April 30, 2033**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com