NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013703.03-R2**
DATE:	**05/05/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Soft-Lite**
CODE:	**2336-1**
REVISION DATE:	**03/12/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Soft-Lite Windows **10250 Phillip Parkway** **Streetsboro, OH 44241**	**Series "Barcelona"** **Vinyl Horizontal Sliding Window** **(SSL 30I)** Configuration: OX Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1854mm(73") H-1422mm(56") Sash: W-899mm(35.38") H-1303mm(51.31") DLO: W-799mm(31.44") H-1203mm(47.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **ASTM E1886-05** **ASTM E1996-09**	**Class R-PG55 1854 x 1422 (73 x 56)-HS** **Design Pressure: ±2633 Pa (55 psf)** **Positive Design Pressure: 2633 Pa (55 psf)** **Negative Design Pressure: 2873 Pa (60 psf)** **Water Penetration resistance Test Pressure: 431 Pa (9.0 psf)** **Wind Zone 4 - Missile Level D**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 03001830/TEL 03001831
Expiration Date: **March 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com