

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013704.05-R3  
DATE: 03/13/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Seves Glass  
CODE: 2322-1  
REVISION DATE: 03/11/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Seves Glass Block, Inc.</b> <b>10576 Broadview Road</b> <b>Broadview Heights, OH 44147</b>	<b>“Residential Hurricane Resistant Windows w/Thickset 90 Series Glass Block &amp; ProVantage Silicone System”</b>  Configuration: O Glazing: 3.88" Thickset® 90 Glass Block Panels  Frame: W-1207mm (47.5") H-2407mm (94.75") Block Size: W-203mm(8") H-203mm(8")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3830 Pa (80 psf) Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 01-44639.03  
Expiration Date: March 31, 2025

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023