

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013707.05-R3  
**DATE:** 05/08/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Atrium  
**CODE:** 2187-1  
**REVISION DATE:** 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Atrium Companies, Inc.</b> <b>300 Welcome Center Blvd.</b> <b>Welcome, NC 27374</b>	<b>Series "700"</b> <b>Vinyl Shaped Fixed Window</b> <b>w/Finless Installation</b>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame: W-1829mm(72") H-1829mm(72") DLO: W-1727mm(68") H-1727mm(68")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class CW-PG50 1829 x 1829 (72 x 72)-FW</b> <b>FW-C50 1829 x 1829 (72 x 72)</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf)</b>

Product Tested By: Underwriters Laboratories  
Report No: SV30476-100715/W-2009  
Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)