

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013716.09-R1
DATE: 08/13/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 08/31/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series "SLPS" Glazed Fiberglass Inswing Patio Door Assembly w/Standard or Mini-Blind Glazing Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" SentryGlas PVB Interlayer/1/8" Annealed Glass Frame: W-3720mm(146.44") H-2500mm(98.44") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17 ASTM E1886-05 ASTM E1996-05/09	Class LC-PG30 3720 x2500 (146 x 98)-SHD Design Pressure: ±1436 Pa (30 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 223 Pa (4.65 psf) Canadian Air Infiltration/Exfiltration Level: A3 Wind Zone 4 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4149-01/NCTL-210-4103-04
Expiration Date: **July 31, 2031**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com