

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013721.01-R3
DATE: 05/23/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Henselstone
CODE: 755-1
REVISION DATE: 06/04/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Henselstone Window & Door Systems 113 Henselstone Lane Amissville, VA 20106	Series "Wood Segmented" Glazed Wood Side Hinged Door Configuration: XXX Glazing: IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass Frame: W-3896mm(153.38") H-3048mm(120") Panel: W-1238mm(48.75") H-2989mm(117.69") DLO: W-1073mm(42.25") H-2759mm(108.63")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Large Missile Impact Rated Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B9271.02-550-18
Expiration Date: May 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.M.D.' or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com