

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013721.02-R3  
DATE: 05/23/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: Henselstone  
CODE: 755-1  
REVISION DATE: 06/04/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Henselstone Window &amp; Door Systems</b>  <b>113 Henselstone Lane</b>  <b>Amissville, VA 20106</b>	<b>Series "Wood Segmented"</b>  <b>Glazed Wood Side Hinged Door</b>  Configuration: XXX Glazing: IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass  Frame: W-3924mm(154.5") H-3048mm(120")  Panel: W-1238mm(48.75") H-2989mm(117.69")  DLO: W-1073mm(42.25") H-2759mm(108.63")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/203-94</b> <b>(With Deviations - Only one specimen tested)</b>	<b>Design Pressure: ±3112 Pa (65 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: B9271.03-550-18  
Expiration Date: May 31, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.' or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)