

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013728-R3  
DATE: 05/24/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: Henselstone  
CODE: 755-1  
REVISION DATE: 06/04/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Henselstone Window &amp; Door Systems</b>  <b>113 Henselstone Lane</b>  <b>Amissville, VA 20106</b>	<b>Glazed Wood Outswing</b>  <b>Side-Hinged French Doors</b>  <b>w/Sidelite</b>  Configuration: OXXX Glazing: IG-1/4" Heat Strengthened Glass/ Laminate-1/4" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/1/4" Heat Strengthened Glass  Frame: W-3962mm(156") H-3048mm(120")  Panel: W-1140mm(44.88") H-2972mm(117")  DLO: W-883mm(34.75") H-2718mm(107")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3112 Pa (65 psf)</b> <b>Positive Design Pressure: 3112 Pa (65 psf)</b> <b>Negative Design Pressure: 3352 Pa (70 psf)</b> <b>Large Missile Impact Rated</b> Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: Aerican Test Lab of South Florida

Report No: ATLSF 1010.02-07

Expiration Date: May 31, 2028

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023