

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013728.05-R3
DATE: 05/24/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Henselstone
CODE: 755-1
REVISION DATE: 06/04/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Henselstone Window & Door Systems 113 Henselstone Lane Amissville, VA 20106	Glazed Wood Outswing Side-Hinged French Doors w/Wood Panel Configuration: XX Glazing: IG-1/4" Heat Strengthened Glass/ Laminate-1/4" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/1/4" Heat Strengthened Glass Frame: W-1511mm(59.5") H-3048mm(120") Panel: W-743mm(29.25") H-2972mm(117") DLO: W-489mm(19.25") H-2003mm(78.88")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Positive Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 4070 Pa (85 psf) Large Missile Impact Rated Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: Aerican Test Lab of South Florida

Report No: ATLSF 1010.02-07

Expiration Date: May 31, 2028

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com