

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013800-R4  
**DATE:** 07/30/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 01/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "1500"</b> <b>Vinyl Single Hung</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1208mm(47.56") H-1511mm(59.5") Sash: W-1141mm(44.94") H-730mm(28.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b>	<b>Class LC-PG50 1208 x 1511 (48 x 60)-H</b> <b>H-LC50 1208 x 1511 (48 x 60)</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19792-1/NCTL-110-15598-1/W-1831/W-1867/W-2112  
Expiration Date: December 31, 2024

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)