

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013824-R1
DATE: 08/24/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Maxim
CODE: 1256-1
REVISION DATE: 03/08/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maxim Industries, Inc. 1630 Terre Colony Court Dallas, TX 75212	Series "DGCM 2017" Aluminum Skylight Configuration: O Glazing: IG - 1/4" Tempered Glass/1/8" Annealed Glass/0.090" DuPont Sentry Glass Interlayer/1/8" Annealed Glass Frame: W-1562mm(61.5") H-1562mm(61.5") DLO: W-1448mm(57") H-1448mm(57")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a/E1996-12 TAS 201/202/203-94	Class CW-PG100 1549 x 1549 (61 x 61)-SKG Design Pressure: 4788 Pa (100 psf) Water Penetration Resistance Test Pressure: 718 Pa (15 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: H0993.01-801-18/H0993.02-801-18/H0993.01-801-18
Expiration Date: May 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. H. O.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122