

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013848-R4
DATE: 09/21/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Seves Glass
CODE: 2322-1
REVISION DATE: 09/11/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Seves Glass Block, Inc. 10576 Broadview Road Broadview Heights, OH 44147 | "12" x 12" x 4" Premiere ®" Glass Block Assembly Configuration: O Glazing: 4" Thick Premiere ® Glass Block Panels Frame: W-1219mm (48") H-1219mm (48") Block Size: W-298mm(11.75") H-298mm(11.75") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------|---|
| TAS 201/202/203-94 | Design Pressure: ±5746 Pa (120 psf) Small Missile Impact Rated |

Product Tested By: Architectural Testing, Inc.
Report No: 66795.02-109-18
Expiration Date: September 30, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com