NOTICE OF PRODUCT CERTIFICATION

1065 ACCREDITED &		
S SNN. ACCREDITADO	CERTIFICATION NO:	NI013849-R2
NOS NA AND MAN	DATE:	<u>09/26/2017</u>
NAMI	CERTIFICATION PROGRAM:	<u>Structural</u>
AN AN AN	COMPANY:	Heister
C. AGEMENT INSTIT	CODE:	<u>2310-1</u>
ERTIFIED PRODUC	REVISION DATE:	<u>06/29/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Heister House Millworks, Inc.	Series "Smooth Star" Glazed Fiberglass	
1937 Troup Valley Road	Side-Hinged Entry Door w/Sidelites	
Mt. Pleasant Mills, PA 17853	w/Wood Frame	
	Configuration: OXO Glazing: Insulating Glass (Tempered)	
	Frame: W-2845mm(112") H-2083mm(82")	
	Panel:W-914mm(36")H-2013mm(79.25")Sidelite:W-914mm(36")H-2013mm(79.25")	
	STP: Pos+48.0 psf Neg-48.0 psf	

SPECIFICATION

AAMA 1702.02-95(02) Federal Manufactured Home Construction & Safety Standard 3280.305 PRODUCT RATING

Manufactured Housing-Passed Wind Zone II/Wind Zone III (Wind Zone III-All areas except 3'0" from endwall or sidewall) (Qualifies Configurations: OX/XO/OXO)

Product Tested By:Architectural Testing, Inc.Report No:A4929.01-501-47Expiration Date:December 31, 2024

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com